

Product Certification Schedule

Schedule No: 186/001/033

Licensee: RR KABEL LTD., PLOT NO 201, 202/1, 202/2, 203 & 327/3, KHANDA ROAD, VILLAGE WAGHODIA, WAGHODIA, VADODARA - 391 760, GUJARAT, INDIA

Factory: RR KABEL LTD., PLOT NO 201, 202/1, 202/2, 203 & 327/3, KHANDA ROAD, VILLAGE WAGHODIA, WAGHODIA, VADODARA - 391 760, GUJARAT, INDIA

Specification: BS EN 50525-3-41:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke

Type of Cable: Heat resistant cables (90°C)
Clause 4.2 - Cables for fixed wiring - H07Z-K
Table B.2 - Cables with flexible conductor (450/750 V)

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 120sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 5 conductor. Insulation - EI5

Origin Thread: Not applicable

Origin Mark: RR KABEL W or -MEW- or RET or Y11

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 03/07/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 23/06/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004